



# SOUTHERN REGIONAL HIGH SCHOOL DISTRICT

---

## OF OCEAN COUNTY

### **Drinking Water Testing Results**

The school district has completed testing for lead in the drinking water at all school facilities. The testing was conducted at every location that is used for drinking or cooking using guidelines developed by the NJ Department of Environmental Protection and the US Environmental Protection Agency. This testing was completed in January 2021. The results of these tests are attached.

During the testing cycle the district identified one location that exceeded the United States EPA threshold limits in the 9/10 High School, four locations that exceeded the United States EPA threshold limits in the 11/12 High School and no locations that exceeded the United States EPA threshold limits in the Middle School. Every location that exceeded the United States EPA threshold limits were immediately shut off and taken out of use. These locations will remain shut off and out of use until fully remediated and retested. Once testing confirms that they no longer exceed the threshold limits the test results will be posted as updates on our website and they will be placed back in service.

The school district will continue to conduct testing to insure the safety of the drinking water in our facilities in compliance with N.J.A.C. 6A:26-12.4.

If there are any questions regarding the school district's testing protocol please feel free to contact the school district's testing program manager, Gary Allegar, at (609)597-9481, extension 4390.

105 CEDAR BRIDGE ROAD, MANAHAWKIN, NJ 08050

PHONE: (609)597-9481, EXTENSION 4209

EMAIL: STERHUNE@SRSD.NET

**Appendix D**  
**Excel Template for Lead Results**

Client : PARS Environmental  
Project ID : Southern Regional M.S., Manahawkin, NJ

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
SRMS-Field Blank	N	P21-13655-01	PAS	NJDEP 15001	12/27/2021	4:25	SM 3113 B	12/29/2021	14:25	-0.23	2.00	1	N	ND
SRMS-1-H Gym A-WF1-P	N	P21-13655-02	PAS	NJDEP 15001	12/27/2021	4:26	SM 3113 B	12/29/2021	14:29	3.40	2.00	1	N	
SRMS-1-H Gym A-WF2-P	N	P21-13655-03	PAS	NJDEP 15001	12/27/2021	4:26	SM 3113 B	12/29/2021	14:46	1.48	2.00	1	N	J
SRMS-1-H Gym A-BT-P	N	P21-13655-04	PAS	NJDEP 15001	12/27/2021	4:26	SM 3113 B	12/29/2021	14:50	-0.23	2.00	1	N	ND
SRMS-1-H D-6-WF1-P	N	P21-13655-05	PAS	NJDEP 15001	12/27/2021	4:29	SM 3113 B	12/29/2021	14:54	1.69	2.00	1	N	J
SRMS-1-H D-6-WF2-P	N	P21-13655-06	PAS	NJDEP 15001	12/27/2021	4:30	SM 3113 B	12/29/2021	15:06	2.97	2.00	1	N	
SRMS-1-Rm B-1-CF-P	N	P21-13655-07	PAS	NJDEP 15001	12/27/2021	4:35	SM 3113 B	12/29/2021	15:10	0.200	2.00	1	N	ND
SRMS-1-H Girl Rm-N-Wing-BT-P	N	P21-13655-08	PAS	NJDEP 15001	12/27/2021	4:36	SM 3113 B	12/29/2021	15:14	-0.66	2.00	1	N	ND
SRMS-1-Girl Rm-N-Wing-WC-P	N	P21-13655-09	PAS	NJDEP 15001	12/27/2021	4:37	SM 3113 B	12/29/2021	15:18	4.68	2.00	1	N	
SRMS-1-H-N-Wing-WF1-P	N	P21-13655-10	PAS	NJDEP 15001	12/27/2021	4:38	SM 3113 B	12/29/2021	15:22	7.24	2.00	1	N	
SRMS-1-H-N-Wing-WF2-P	N	P21-13655-11	PAS	NJDEP 15001	12/27/2021	4:38	SM 3113 B	12/29/2021	15:26	5.53	2.00	1	N	
SRMS-1-H D-3-WF-P	N	P21-13655-12	PAS	NJDEP 15001	12/27/2021	4:40	SM 3113 B	12/29/2021	15:30	1.26	2.00	1	N	J
SRMS-1-H D-2 Faculty Rm-TL-P	N	P21-13655-13	PAS	NJDEP 15001	12/27/2021	4:42	SM 3113 B	12/29/2021	15:34	2.76	2.00	1	N	
SRMS-1-Rm B-11-TL1-P	N	P21-13655-14	PAS	NJDEP 15001	12/27/2021	4:42	SM 3113 B	12/29/2021	15:38	1.69	2.00	1	N	J
SRMS-1-Rm B-11-TL2-P	N	P21-13655-15	PAS	NJDEP 15001	12/27/2021	4:45	SM 3113 B	12/29/2021	15:50	1.48	2.00	1	N	J
SRMS-1-H E-10-BT-P	N	P21-13655-16	PAS	NJDEP 15001	12/27/2021	4:47	SM 3113 B	12/29/2021	15:54	-0.44	2.00	1	N	ND
SRMS-1-H E-10-WF-P	N	P21-13655-17	PAS	NJDEP 15001	12/27/2021	4:48	SM 3113 B	12/29/2021	15:58	2.12	2.00	1	N	
SRMS-1-H E-5-BT-P	N	P21-13655-18	PAS	NJDEP 15001	12/27/2021	4:49	SM 3113 B	12/29/2021	16:02	-0.66	2.00	1	N	ND
SRMS-1-H E-5-WF1-P	N	P21-13655-19	PAS	NJDEP 15001	12/27/2021	4:49	SM 3113 B	12/29/2021	16:06	2.76	2.00	1	N	
SRMS-1-H E-5-WF2-P	N	P21-13655-20	PAS	NJDEP 15001	12/27/2021	4:50	SM 3113 B	12/29/2021	16:10	3.18	2.00	1	N	
SRMS-1-Cafe-WC1-P	N	P21-13655-21	PAS	NJDEP 15001	12/27/2021	4:52	SM 3113 B	12/29/2021	16:14	-0.44	2.00	1	N	ND
SRMS-1-Cafe-BT-P	N	P21-13655-22	PAS	NJDEP 15001	12/27/2021	4:52	SM 3113 B	12/29/2021	16:51	-0.23	2.00	1	N	ND
SRMS-1-Kit-FP1-P	N	P21-13655-23	PAS	NJDEP 15001	12/27/2021	4:55	SM 3113 B	12/29/2021	16:55	-0.02	2.00	1	N	ND
SRMS-1-Kit-FP2-P	N	P21-13655-24	PAS	NJDEP 15001	12/27/2021	4:55	SM 3113 B	12/29/2021	16:59	9.80	2.00	1	N	
SRMS-1-Kit-IM-P	N	P21-13655-25	PAS	NJDEP 15001	12/27/2021	4:56	SM 3113 B	12/29/2021	17:03	-0.02	2.00	1	N	ND
SRMS-1-E-3-CF1-P	N	P21-13655-26	PAS	NJDEP 15001	12/27/2021	5:00	SM 3113 B	12/29/2021	17:07	0.840	2.00	1	N	ND
SRMS-1-E-3-CF2-P	N	P21-13655-27	PAS	NJDEP 15001	12/27/2021	5:00	SM 3113 B	12/29/2021	17:11	1.05	2.00	1	N	J
SRMS-1-E-3-CF3-P	N	P21-13655-28	PAS	NJDEP 15001	12/27/2021	5:01	SM 3113 B	12/29/2021	17:15	0.840	2.00	1	N	ND
SRMS-1-E-3-CF4-P	N	P21-13655-29	PAS	NJDEP 15001	12/27/2021	5:01	SM 3113 B	12/29/2021	17:27	0.200	2.00	1	N	ND
SRMS-1-E-3-CF5-P	N	P21-13655-30	PAS	NJDEP 15001	12/27/2021	5:02	SM 3113 B	12/29/2021	17:31	0.840	2.00	1	N	ND
SRMS-1-E-3-CF6-P	N	P21-13655-31	PAS	NJDEP 15001	12/27/2021	5:02	SM 3113 B	12/29/2021	17:35	0.410	2.00	1	N	ND
SRMS-1-Lib Office-TL-P	N	P21-13655-32	PAS	NJDEP 15001	12/27/2021	5:03	SM 3113 B	12/29/2021	17:39	2.54	2.00	1	N	
SRMS-1-H A-1-BT-P	N	P21-13655-33	PAS	NJDEP 15001	12/27/2021	5:05	SM 3113 B	12/29/2021	17:43	-0.02	2.00	1	N	ND
SRMS-1-Nurse Office-NS-P	N	P21-13655-34	PAS	NJDEP 15001	12/27/2021	5:06	SM 3113 B	12/29/2021	17:47	1.69	2.00	1	N	J
SRMS-1-Main Office-WC-P	N	P21-13655-35	PAS	NJDEP 15001	12/27/2021	5:07	SM 3113 B	12/29/2021	17:51	12.8	2.00	1	N	
SRMS-1-Main Office-TL-P	N	P21-13655-36	PAS	NJDEP 15001	12/27/2021	5:08	SM 3113 B	12/29/2021	17:55	1.26	2.00	1	N	J

**Appendix D**  
**Excel Template for Lead Results**

Client : PARS Environmental  
Project ID : Southern Regional H.S. 9/10, Manahawkin, NJ

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
SR9-Field Blank	N	P21-13656-01	PAS	NJDEP 15001	12/28/2021	5:44	SM 3113 B	1/3/2022	11:40	-0.39	2.00	1	N	ND
SR9-1-Lib Office-TL-P	N	P21-13656-02	PAS	NJDEP 15001	12/28/2021	5:45	SM 3113 B	1/3/2022	14:43	2.29	2.00	1	N	
SR9-1-H5-7-BT-P	N	P21-13656-03	PAS	NJDEP 15001	12/28/2021	5:46	SM 3113 B	1/3/2022	12:12	-0.57	2.00	1	N	ND
SR9-1-H4-1-WF-P	N	P21-13656-04	PAS	NJDEP 15001	12/28/2021	5:47	SM 3113 B	1/3/2022	12:15	4.43	2.00	1	N	
SR9-1-Rm6-2-TL-P	N	P21-13656-05	PAS	NJDEP 15001	12/28/2021	5:48	SM 3113 B	1/3/2022	12:19	0.140	2.00	1	N	ND
SR9-1-H6-3-WF-P	N	P21-13656-06	PAS	NJDEP 15001	12/28/2021	5:49	SM 3113 B	1/3/2022	12:22	10.3	2.00	1	N	
SR9-1-H8-5-WC1-P	N	P21-13656-07	PAS	NJDEP 15001	12/28/2021	5:50	SM 3113 B	1/3/2022	12:26	-0.57	2.00	1	N	ND
SR9-1-H8-5-WC2-P	N	P21-13656-08	PAS	NJDEP 15001	12/28/2021	5:51	SM 3113 B	1/3/2022	12:30	-0.39	2.00	1	N	ND
SR9-1-H8-5-BT-P	N	P21-13656-09	PAS	NJDEP 15001	12/28/2021	5:52	SM 3113 B	1/3/2022	12:33	-0.57	2.00	1	N	ND
SR9-1-8-4-WC1-P	N	P21-13656-10	PAS	NJDEP 15001	12/28/2021	5:53	SM 3113 B	1/3/2022	12:37	1.21	2.00	1	N	J
SR9-1-8-4-WC2-P	N	P21-13656-11	PAS	NJDEP 15001	12/28/2021	5:54	SM 3113 B	1/3/2022	12:41	1.39	2.00	1	N	J
SR9-1-H4-1-BT-P	N	P21-13656-12	PAS	NJDEP 15001	12/28/2021	5:55	SM 3113 B	1/3/2022	12:59	-0.57	2.00	1	N	ND
SR9-1-H-J5-BT-P	N	P21-13656-13	PAS	NJDEP 15001	12/28/2021	5:56	SM 3113 B	1/3/2022	13:03	-0.57	2.00	1	N	ND
SR9-1-H7-O-WF-P	N	P21-13656-14	PAS	NJDEP 15001	12/28/2021	5:57	SM 3113 B	1/3/2022	13:06	0.860	2.00	1	N	ND
SR9-1-H Cafe-BT-P	N	P21-13656-15	PAS	NJDEP 15001	12/28/2021	5:59	SM 3113 B	1/3/2022	13:10	-0.57	2.00	1	N	ND
SR9-1-H1-6-WF-P	N	P21-13656-16	PAS	NJDEP 15001	12/28/2021	6:02	SM 3113 B	1/3/2022	13:14	7.64	2.00	1	N	
SR9-1-Rm1-2-CF-P	N	P21-13656-17	PAS	NJDEP 15001	12/28/2021	6:04	SM 3113 B	1/3/2022	13:18	-0.39	2.00	1	N	ND
SR9-1-Cafe-WC1-P	N	P21-13656-18	PAS	NJDEP 15001	12/28/2021	6:06	SM 3113 B	1/3/2022	13:22	-0.57	2.00	1	N	ND
SR9-1-Kit-FP1-P	N	P21-13656-19	PAS	NJDEP 15001	12/28/2021	6:07	SM 3113 B	1/3/2022	13:25	0.500	2.00	1	N	ND
SR9-1-Kit-FP2-P	N	P21-13656-20	PAS	NJDEP 15001	12/28/2021	6:08	SM 3113 B	1/3/2022	13:29	4.07	2.00	1	N	
SR9-1-Kit-FP3-P	N	P21-13656-21	PAS	NJDEP 15001	12/28/2021	6:09	SM 3113 B	1/3/2022	13:49	2.11	2.00	1	N	
SR9-1-Kit-KT1-P	N	P21-13656-22	PAS	NJDEP 15001	12/28/2021	6:10	SM 3113 B	1/3/2022	14:04	1.39	2.00	1	N	J
SR9-1-Kit-KT2-P	N	P21-13656-23	PAS	NJDEP 15001	12/28/2021	6:11	SM 3113 B	1/3/2022	14:08	8.36	2.00	1	N	
SR9-1-Kit-IM-P	N	P21-13656-24	PAS	NJDEP 15001	12/28/2021	6:12	SM 3113 B	1/3/2022	14:11	-0.21	2.00	1	N	ND
SR9-1-Kit-SP-P	N	P21-13656-25	PAS	NJDEP 15001	12/28/2021	6:13	SM 3113 B	1/3/2022	14:15	0.500	2.00	1	N	ND
SR9-1-Nurse-NS-P	N	P21-13656-26	PAS	NJDEP 15001	12/28/2021	6:14	SM 3113 B	1/3/2022	14:18	1.04	2.00	1	N	J
SR9-1-B Locker Rm-WC-P	N	P21-13656-27	PAS	NJDEP 15001	12/28/2021	6:15	SM 3113 B	1/3/2022	14:29	-0.21	2.00	1	N	ND
SR9-1-B Locker Rm-IM-P	N	P21-13656-28	PAS	NJDEP 15001	12/28/2021	6:16	SM 3113 B	1/3/2022	14:33	-0.04	2.00	1	N	ND
SR9-1-B Locker Rm-BT-P	N	P21-13656-29	PAS	NJDEP 15001	12/28/2021	6:17	SM 3113 B	1/3/2022	14:37	-0.21	2.00	1	N	ND
SR9-1-H Audit-WF-P	N	P21-13656-30	PAS	NJDEP 15001	12/28/2021	6:18	SM 3113 B	1/3/2022	14:40	3.54	2.00	1	N	
SR9-1-H Audit-BT-P	N	P21-13656-31	PAS	NJDEP 15001	12/28/2021	6:19	SM 3113 B	1/3/2022	14:44	-0.21	2.00	1	N	ND
SR9-1-H Guidance-WF-P	N	P21-13656-32	PAS	NJDEP 15001	12/28/2021	6:22	SM 3113 B	1/3/2022	14:48	4.25	2.00	1	N	
<b>SR9-1-G Locker Rm-WF-P</b>	<b>N</b>	<b>P21-13656-33</b>	<b>PAS</b>	<b>NJDEP 15001</b>	<b>12/28/2021</b>	<b>6:25</b>	<b>SM 3113 B</b>	<b>1/3/2022</b>	<b>15:13</b>	<b>19.9</b>	<b>4.00</b>	<b>2</b>	<b>N</b>	
SR9-1-G Locker Office-TL-P	N	P21-13656-34	PAS	NJDEP 15001	12/28/2021	6:26	SM 3113 B	1/3/2022	14:55	1.39	2.00	1	N	J
SR9-1-H Gym C-BT-P	N	P21-13656-35	PAS	NJDEP 15001	12/28/2021	6:29	SM 3113 B	1/3/2022	15:17	-0.39	2.00	1	N	ND
SR9-1-Rm9-12-CF1-P	N	P21-13656-36	PAS	NJDEP 15001	12/28/2021	6:31	SM 3113 B	1/3/2022	15:20	-0.04	2.00	1	N	ND
SR9-1-Rm9-12-CF2-P	N	P21-13656-37	PAS	NJDEP 15001	12/28/2021	6:32	SM 3113 B	1/3/2022	15:24	0.680	2.00	1	N	ND
SR9-1-Rm9-5-1-CF-P	N	P21-13656-38	PAS	NJDEP 15001	12/28/2021	6:34	SM 3113 B	1/3/2022	15:28	-0.21	2.00	1	N	ND
SR9-1-Rm9-4-HEC1-P	N	P21-13656-39	PAS	NJDEP 15001	12/28/2021	6:36	SM 3113 B	1/3/2022	15:31	-0.21	2.00	1	N	ND
SR9-1-Rm9-4-HEC2-P	N	P21-13656-40	PAS	NJDEP 15001	12/28/2021	6:37	SM 3113 B	1/3/2022	15:35	0.680	2.00	1	N	ND
SR9-1-Rm9-4-HEC3-P	N	P21-13656-41	PAS	NJDEP 15001	12/28/2021	6:38	SM 3113 B	1/3/2022	15:39	-0.21	2.00	1	N	ND
SR9-1-Rm9-4-HEC4-P	N	P21-13656-42	PAS	NJDEP 15001	12/28/2021	6:39	SM 3113 B	1/3/2022	16:10	-0.39	2.00	1	N	ND
SR9-1-Rm9-4-HEC5-P	N	P21-13656-43	PAS	NJDEP 15001	12/28/2021	6:40	SM 3113 B	1/3/2022	16:14	0.860	2.00	1	N	ND
SR9-1-Rm9-4-HEC-SP-P	N	P21-13656-44	PAS	NJDEP 15001	12/28/2021	6:41	SM 3113 B	1/3/2022	16:17	-0.39	2.00	1	N	ND
SR9-1-Rm9-3-HEC1-P	N	P21-13656-45	PAS	NJDEP 15001	12/28/2021	6:43	SM 3113 B	1/3/2022	16:21	-0.39	2.00	1	N	ND
SR9-1-Rm9-3-HEC2-P	N	P21-13656-46	PAS	NJDEP 15001	12/28/2021	6:44	SM 3113 B	1/3/2022	15:37	0.025	2.00	1	N	ND
SR9-1-Rm9-3-HEC3-P	N	P21-13656-47	PAS	NJDEP 15001	12/28/2021	6:45	SM 3113 B	1/3/2022	15:41	0.230	2.00	1	N	ND
SR9-1-Rm9-3-HEC4-P	N	P21-13656-48	PAS	NJDEP 15001	12/28/2021	6:46	SM 3113 B	1/3/2022	15:45	0.630	2.00	1	N	ND
SR9-1-Rm9-3-HEC5-P	N	P21-13656-49	PAS	NJDEP 15001	12/28/2021	6:47	SM 3113 B	1/3/2022	15:57	-0.18	2.00	1	N	ND
SR9-1-Rm9-3-HEC-SP-P	N	P21-13656-50	PAS	NJDEP 15001	12/28/2021	6:48	SM 3113 B	1/3/2022	16:01	1.23	2.00	1	N	J
SR9-1-Rm9-3-IM-P	N	P21-13656-51	PAS	NJDEP 15001	12/28/2021	6:49	SM 3113 B	1/3/2022	16:05	-0.18	2.00	1	N	ND
SR9-1-Rm9-10-CF1-P	N	P21-13656-52	PAS	NJDEP 15001	12/28/2021	6:52	SM 3113 B	1/3/2022	16:09	0.430	2.00	1	N	ND
SR9-1-Rm9-10-CF2-P	N	P21-13656-53	PAS	NJDEP 15001	12/28/2021	6:53	SM 3113 B	1/3/2022	16:13	1.03	2.00	1	N	J
SR9-1-Rm9-9-CF-P	N	P21-13656-54	PAS	NJDEP 15001	12/28/2021	6:55	SM 3113 B	1/3/2022	16:16	0.830	2.00	1	N	ND
SR9-1-Rm9-6-CF-P	N	P21-13656-55	PAS	NJDEP 15001	12/28/2021	6:57	SM 3113 B	1/3/2022	16:20	0.230	2.00	1	N	ND

**Appendix D**  
**Excel Template for Lead Results**

Client : PARS Environmental  
Project ID : Southern Regional H.S. 11/12, 90 Cedar Bridge Road

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
SR11-Field Blank	N	P21-13654-01	PAS	NJDEP 15001	12/28/2021	4:32	SM 3113 B	12/30/2021	10:57	-0.48	2.00	1	N	ND
SR11-1-H 108-WC1-P	N	P21-13654-02	PAS	NJDEP 15001	12/28/2021	4:37	SM 3113 B	12/30/2021	11:01	3.43	2.00	1	N	
SR11-1-H 108-WC2-P	N	P21-13654-03	PAS	NJDEP 15001	12/28/2021	4:37	SM 3113 B	12/30/2021	11:25	7.56	2.00	1	N	
SR11-1-H 108-WC3-P	N	P21-13654-04	PAS	NJDEP 15001	12/28/2021	4:38	SM 3113 B	12/30/2021	11:29	1.36	2.00	1	N	J
SR11-1-H 108-WC4-P	N	P21-13654-05	PAS	NJDEP 15001	12/28/2021	4:38	SM 3113 B	12/30/2021	11:33	2.51	2.00	1	N	
SR11-1-NS Office EX1-NS1-P	N	P21-13654-06	PAS	NJDEP 15001	12/28/2021	4:40	SM 3113 B	12/30/2021	11:37	3.43	2.00	1	N	
SR11-1-NS Office EX2-NS2-P	N	P21-13654-07	PAS	NJDEP 15001	12/28/2021	4:41	SM 3113 B	12/30/2021	11:41	1.59	2.00	1	N	J
SR11-1-NS Office EX3-NS3-P	N	P21-13654-08	PAS	NJDEP 15001	12/28/2021	4:41	SM 3113 B	12/30/2021	11:45	0.670	2.00	1	N	ND
SR11-1-H NS Office-WC1-P	N	P21-13654-09	PAS	NJDEP 15001	12/28/2021	4:43	SM 3113 B	12/30/2021	11:49	-0.02	2.00	1	N	ND
SR11-1-H NS Office-WC2-P	N	P21-13654-10	PAS	NJDEP 15001	12/28/2021	4:43	SM 3113 B	12/30/2021	12:06	1.59	2.00	1	N	J
SR11-1-H NS Office-BT1-P	N	P21-13654-11	PAS	NJDEP 15001	12/28/2021	4:44	SM 3113 B	12/30/2021	12:10	-0.48	2.00	1	N	ND
SR11-1-H NS Office-WC3-P	N	P21-13654-12	PAS	NJDEP 15001	12/28/2021	4:45	SM 3113 B	12/30/2021	12:18	0.670	2.00	1	N	ND
SR11-1-H Weight Rm-BT-P	N	P21-13654-13	PAS	NJDEP 15001	12/28/2021	4:47	SM 3113 B	12/30/2021	12:22	-0.48	2.00	1	N	ND
SR11-1-Weight Rm-WC-P	N	P21-13654-14	PAS	NJDEP 15001	12/28/2021	4:47	SM 3113 B	12/30/2021	12:26	-0.71	2.00	1	N	ND
SR11-1-G Locker Rm-IM-P	N	P21-13654-15	PAS	NJDEP 15001	12/28/2021	4:49	SM 3113 B	12/30/2021	12:31	-0.71	2.00	1	N	ND
SR11-1-G Locker Rm-WC1-P	N	P21-13654-16	PAS	NJDEP 15001	12/28/2021	4:51	SM 3113 B	12/30/2021	12:35	12.9	2.00	1	N	
SR11-1-G Locker Rm-WC2-P	N	P21-13654-17	PAS	NJDEP 15001	12/28/2021	4:51	SM 3113 B	12/30/2021	15:33	36.7	10.0	5	N	
SR11-1-G Team Rm-WC1-P	N	P21-13654-18	PAS	NJDEP 15001	12/28/2021	4:52	SM 3113 B	12/30/2021	12:51	4.80	2.00	1	N	
SR11-1-G Team Rm-WC2-P	N	P21-13654-19	PAS	NJDEP 15001	12/28/2021	4:52	SM 3113 B	12/30/2021	12:55	7.33	2.00	1	N	
SR11-1-Wrestling Team Rm-WC1-P	N	P21-13654-20	PAS	NJDEP 15001	12/28/2021	4:54	SM 3113 B	12/30/2021	12:59	5.95	2.00	1	N	
SR11-1-Wrestling Team Rm-WC2-P	N	P21-13654-21	PAS	NJDEP 15001	12/28/2021	4:54	SM 3113 B	12/30/2021	15:37	18.8	4.00	2	N	
SR11-1-H Wrestling-BT-P	N	P21-13654-22	PAS	NJDEP 15001	12/28/2021	4:55	SM 3113 B	12/30/2021	13:19	-0.48	2.00	1	N	ND
SR11-1-H Wrestling-WC-P	N	P21-13654-23	PAS	NJDEP 15001	12/28/2021	4:55	SM 3113 B	12/30/2021	13:23	-0.94	2.00	1	N	ND
SR11-1-B Locker Rm-IM-P	N	P21-13654-24	PAS	NJDEP 15001	12/28/2021	5:00	SM 3113 B	12/30/2021	13:47	-0.94	2.00	1	N	ND
SR11-1-B Locker Rm-WC1-P	N	P21-13654-25	PAS	NJDEP 15001	12/28/2021	5:01	SM 3113 B	12/30/2021	13:51	2.05	2.00	1	N	
SR11-1-B Locker Rm-WC2-P	N	P21-13654-26	PAS	NJDEP 15001	12/28/2021	5:02	SM 3113 B	12/30/2021	13:55	4.57	2.00	1	N	
SR11-1-B Team Rm-WC1-P	N	P21-13654-27	PAS	NJDEP 15001	12/28/2021	5:03	SM 3113 B	12/30/2021	15:45	41.3	10.0	5	N	
SR11-1-B Team Rm-WC2-P	N	P21-13654-28	PAS	NJDEP 15001	12/28/2021	5:04	SM 3113 B	12/30/2021	15:49	25.2	4.00	2	N	
SR11-1-Child ST-TL-P	N	P21-13654-29	PAS	NJDEP 15001	12/28/2021	5:06	SM 3113 B	12/30/2021	14:07	-0.25	2.00	1	N	ND
SR11-1-Lib-WC1-P	N	P21-13654-30	PAS	NJDEP 15001	12/28/2021	5:08	SM 3113 B	12/30/2021	14:11	0.440	2.00	1	N	ND
SR11-1-Lib-WC2-P	N	P21-13654-31	PAS	NJDEP 15001	12/28/2021	5:08	SM 3113 B	1/3/2022	12:21	2.56	2.00	1	N	
SR11-1-Lib Office-TL-P	N	P21-13654-32	PAS	NJDEP 15001	12/28/2021	5:09	SM 3113 B	1/3/2022	12:37	0.160	2.00	1	N	ND
SR11-1-Home Eco-EC1-P	N	P21-13654-33	PAS	NJDEP 15001	12/28/2021	5:11	SM 3113 B	1/3/2022	12:49	-0.06	2.00	1	N	ND
SR11-1-Home Eco-EC2-P	N	P21-13654-34	PAS	NJDEP 15001	12/28/2021	5:11	SM 3113 B	1/3/2022	12:53	-0.28	2.00	1	N	ND
SR11-1-Home Eco-EC3-P	N	P21-13654-35	PAS	NJDEP 15001	12/28/2021	5:12	SM 3113 B	1/3/2022	12:57	-0.28	2.00	1	N	ND
SR11-1-Home Eco-EC4-P	N	P21-13654-36	PAS	NJDEP 15001	12/28/2021	5:12	SM 3113 B	1/3/2022	13:01	-0.50	2.00	1	N	ND
SR11-1-Home Eco-EC5-P	N	P21-13654-37	PAS	NJDEP 15001	12/28/2021	5:13	SM 3113 B	1/3/2022	13:05	-0.71	2.00	1	N	ND
SR11-1-Home Eco-EC6-P	N	P21-13654-38	PAS	NJDEP 15001	12/28/2021	5:13	SM 3113 B	1/3/2022	13:09	-0.71	2.00	1	N	ND
SR11-1-H Cafe-WC-P	N	P21-13654-39	PAS	NJDEP 15001	12/28/2021	5:14	SM 3113 B	1/3/2022	13:13	-0.50	2.00	1	N	ND
SR11-1-H Cafe-BT-P	N	P21-13654-40	PAS	NJDEP 15001	12/28/2021	5:14	SM 3113 B	1/3/2022	13:17	-0.50	2.00	1	N	ND
SR11-1-Cafe-WC1-P	N	P21-13654-41	PAS	NJDEP 15001	12/28/2021	5:16	SM 3113 B	1/3/2022	13:21	2.99	2.00	1	N	
SR11-1-Cafe-WC2-P	N	P21-13654-42	PAS	NJDEP 15001	12/28/2021	5:17	SM 3113 B	1/3/2022	13:46	-0.50	2.00	1	N	ND
SR11-1-Cafe Teacher-TL-P	N	P21-13654-43	PAS	NJDEP 15001	12/28/2021	5:18	SM 3113 B	1/3/2022	13:50	-0.50	2.00	1	N	ND
SR11-1-Kit-KF1-P	N	P21-13654-44	PAS	NJDEP 15001	12/28/2021	5:20	SM 3113 B	1/3/2022	13:54	1.90	2.00	1	N	J
SR11-1-Kit-IM-P	N	P21-13654-45	PAS	NJDEP 15001	12/28/2021	5:21	SM 3113 B	1/3/2022	13:59	-0.93	2.00	1	N	ND
SR11-1-Rm101-CF1-P	N	P21-13654-46	PAS	NJDEP 15001	12/28/2021	5:23	SM 3113 B	1/3/2022	14:03	-0.50	2.00	1	N	ND
SR11-1-Rm101-CF2-P	N	P21-13654-47	PAS	NJDEP 15001	12/28/2021	5:23	SM 3113 B	1/3/2022	14:07	-0.28	2.00	1	N	ND
SR11-2-H 208-BT-P	N	P21-13654-48	PAS	NJDEP 15001	12/28/2021	5:29	SM 3113 B	1/3/2022	14:19	-0.71	2.00	1	N	ND
SR11-2-H 208-WC1-P	N	P21-13654-49	PAS	NJDEP 15001	12/28/2021	5:29	SM 3113 B	1/3/2022	14:23	2.77	2.00	1	N	
SR11-2-H 208-WC2-P	N	P21-13654-50	PAS	NJDEP 15001	12/28/2021	5:30	SM 3113 B	1/3/2022	14:31	1.68	2.00	1	N	J
SR11-2-H 208-WC3-P	N	P21-13654-51	PAS	NJDEP 15001	12/28/2021	5:30	SM 3113 B	1/3/2022	14:35	9.53	2.00	1	N	
SR11-2-H 224-WC-P	N	P21-13654-52	PAS	NJDEP 15001	12/28/2021	5:32	SM 3113 B	1/3/2022	14:51	1.03	2.00	1	N	J
SR11-2-H 227-BT-P	N	P21-13654-53	PAS	NJDEP 15001	12/28/2021	5:33	SM 3113 B	1/3/2022	14:55	-0.71	2.00	1	N	ND
SR11-2-Teacher Lounge-TL-P	N	P21-13654-54	PAS	NJDEP 15001	12/28/2021	5:34	SM 3113 B	1/3/2022	15:07	-1.15	2.00	1	N	ND