



SOUTHERN REGIONAL HIGH SCHOOL DISTRICT

OF OCEAN COUNTY

Drinking Water Testing Results

The school district has completed testing for lead in the drinking water at all school facilities. The testing was conducted at every location that is used for drinking or cooking using guidelines developed by the NJ Department of Environmental Protection and the US Environmental Protection Agency. This testing was completed in August 2020. The results of these tests are attached.

During the testing cycle the district identified five locations that exceeded the United States EPA threshold limits in the 9/10 High School, no locations that exceeded the United States EPA threshold limits in the 11/12 High School and two locations that exceeded the United States EPA threshold limits in the Middle School. Every location that exceeded the United States EPA threshold limits were immediately shut off and taken out of use. These locations will remain shut off and out of use unit fully remediated and retested. Once testing confirms that they no longer exceed the threshold limits the test results will be posted as updates on our website and they will be placed back in service.

The school district will continue to conduct testing to insure the safety of the drinking water in our facilities in compliance with N.J.A.C. 6A:26-12.4.

If there are any questions regarding the school district's testing protocol please feel free to contact the school district's testing program manager, Gary Allegar, at (609)597-9481, extension 4390.

105 CEDAR BRIDGE ROAD, MANAHAWKIN, NJ 08050

PHONE: (609)597-9481, EXTENSION 4209

EMAIL: STERHUNE@SRSD.NET



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Jessica Perrini
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691

8/31/2020

Phone: (609) 890-7277
Fax: (609) 890-9116

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 8/17/2020. The results are tabulated on the attached data pages for the following client designated project:

Southern Regional HS 9/10

The reference number for these samples is EMSL Order #012008720. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012008720
 CustomerID: PARS51
 CustomerPO: 1037-21
 ProjectID:

Attn: **Jessica Perrini**
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691

Phone: (609) 890-7277
 Fax: (609) 890-9116
 Received: 8/17/2020 09:00 AM

Project: Southern Regional HS 9/10

Analytical Results

Client Sample Description SR9-Field Blank
 FB **Collected:** 8/14/2020 9:50:00 AM **Lab ID:** 012008720-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 20:40

Client Sample Description SRP-1-H4101-WF
 1 **Collected:** 8/14/2020 9:52:00 AM **Lab ID:** 012008720-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.02	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 20:41

Client Sample Description SR9-1-LIBOFFICE-TF
 2 **Collected:** 8/14/2020 10:00:00 AM **Lab ID:** 012008720-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.35	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 20:43

Client Sample Description SR9-1-H5-7-BF
 3 **Collected:** 8/14/2020 10:05:00 AM **Lab ID:** 012008720-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 20:44

Client Sample Description SR9-1-H4-1-WF
 4 **Collected:** 8/14/2020 10:07:00 AM **Lab ID:** 012008720-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.28	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 20:45

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012008720
 CustomerID: PARS51
 CustomerPO: 1037-21
 ProjectID:

Attn: **Jessica Perrini**
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691

Phone: (609) 890-7277
 Fax: (609) 890-9116
 Received: 8/17/2020 09:00 AM

Project: Southern Regional HS 9/10

Analytical Results

Client Sample Description SR9-1-RM6-2-TF
5
Collected: 8/14/2020 10:08:00 AM
Lab ID: 012008720-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.27	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 21:22

Client Sample Description SR9-1-H6-3-WF
6
Collected: 8/14/2020 10:09:00 AM
Lab ID: 012008720-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.70	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 21:26

Client Sample Description SR9-1-H8-5-WC1
7
Collected: 8/14/2020 10:15:00 AM
Lab ID: 012008720-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 21:27

Client Sample Description SR9-1-H8-5-WC2
8
Collected: 8/14/2020 10:16:00 AM
Lab ID: 012008720-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 21:29

Client Sample Description SR9-1-H2-1-WF
9
Collected: 8/14/2020 10:25:00 AM
Lab ID: 012008720-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.63	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 21:30

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012008720

CustomerID: PARS51

CustomerPO: 1037-21

ProjectID:

Attn: **Jessica Perrini**
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691

Phone: (609) 890-7277
 Fax: (609) 890-9116
 Received: 8/17/2020 09:00 AM

Project: Southern Regional HS 9/10

Analytical Results

Client Sample Description SR9-1-H7-0-WF
10
Collected: 8/14/2020
10:30:00 AM
Lab ID: 012008720-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 21:35

Client Sample Description SR9-1-HCAFE-BF
11
Collected: 8/14/2020
10:31:00 AM
Lab ID: 012008720-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 21:41

Client Sample Description SR9-1-H1-6-WF
12
Collected: 8/14/2020
10:35:00 AM
Lab ID: 012008720-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.76	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 21:43

Client Sample Description SR9-1-RM1-2-CF
13
Collected: 8/14/2020
10:40:00 AM
Lab ID: 012008720-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.26	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 21:44

Client Sample Description SR9-1-CAFE-WC1
14
Collected: 8/14/2020
10:41:00 AM
Lab ID: 012008720-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	14.1	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 21:45

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012008720
 CustomerID: PARS51
 CustomerPO: 1037-21
 ProjectID:

Attn: **Jessica Perrini**
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691

Phone: (609) 890-7277
 Fax: (609) 890-9116
 Received: 8/17/2020 09:00 AM

Project: Southern Regional HS 9/10

Analytical Results

Client Sample Description SR9-1-CAFE-WC2
 15 **Collected:** 8/14/2020 10:42:00 AM **Lab ID:** 012008720-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 21:46

Client Sample Description SR9-1-KIT-FP1
 16 **Collected:** 8/14/2020 10:45:00 AM **Lab ID:** 012008720-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.4	1.00 µg/L	8/25/2020 JA	8/26/2020 KB 16:13

Client Sample Description SR9-1-KIT-FP2
 17 **Collected:** 8/14/2020 10:46:00 AM **Lab ID:** 012008720-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	70.3	1.00 µg/L	8/25/2020 JA	8/26/2020 KB 16:15

Client Sample Description SR9-1-KIT-F33
 18 **Collected:** 8/14/2020 10:48:00 AM **Lab ID:** 012008720-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	28.5	1.00 µg/L	8/25/2020 JA	8/26/2020 KB 16:17

Client Sample Description SR9-1-SJ-5-WF2
 19 **Collected:** 8/14/2020 10:50:00 AM **Lab ID:** 012008720-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	18.7	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 21:48

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012008720

CustomerID: PARS51

CustomerPO: 1037-21

ProjectID:

Attn: **Jessica Perrini**
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691

Phone: (609) 890-7277
 Fax: (609) 890-9116
 Received: 8/17/2020 09:00 AM

Project: Southern Regional HS 9/10

Analytical Results

Client Sample Description SR9-1-NURSE-NS
20 **Collected:** 8/14/2020
10:56:00 AM **Lab ID:** 012008720-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.13	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 21:49

Client Sample Description SR9-1-B-LOCKERRM-WC
21 **Collected:** 8/14/2020
10:59:00 AM **Lab ID:** 012008720-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	24.7	1.00 µg/L	8/25/2020 JA	8/26/2020 KB 16:19

Client Sample Description SR9-1-B-LOCKERRM-IM
22 **Collected:** 8/14/2020
11:01:00 AM **Lab ID:** 012008720-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 21:50

Client Sample Description SR9-1-HAUDIT-WF
23 **Collected:** 8/14/2020
11:02:00 AM **Lab ID:** 012008720-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.02	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 21:51

Client Sample Description SR9-1-HAUDIT-BF
24 **Collected:** 8/14/2020
11:07:00 AM **Lab ID:** 012008720-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 21:53

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012008720
 CustomerID: PARS51
 CustomerPO: 1037-21
 ProjectID:

Attn: **Jessica Perrini**
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691

Phone: (609) 890-7277
 Fax: (609) 890-9116
 Received: 8/17/2020 09:00 AM

Project: Southern Regional HS 9/10

Analytical Results

Client Sample Description SR9-1-HGUIDANCE-WF
25 **Collected:** 8/14/2020 11:11:00 AM **Lab ID:** 012008720-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.89	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 21:59

Client Sample Description SR9-1-GLOCKERRM-WF
26 **Collected:** 8/14/2020 11:15:00 AM **Lab ID:** 012008720-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.91	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 22:00

Client Sample Description SR9-1-G-LOCKERRMOFFICE-TF
27 **Collected:** 8/14/2020 11:17:00 AM **Lab ID:** 012008720-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.04	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 22:02

Client Sample Description SR9-1-HGYMC-BF
28 **Collected:** 8/14/2020 11:19:00 AM **Lab ID:** 012008720-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 22:03

Client Sample Description SR9-1-RM9-12-CF1
29 **Collected:** 8/14/2020 11:22:00 AM **Lab ID:** 012008720-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.14	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 22:04

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012008720
 CustomerID: PARS51
 CustomerPO: 1037-21
 ProjectID:

Attn: **Jessica Perrini**
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691

Phone: (609) 890-7277
 Fax: (609) 890-9116
 Received: 8/17/2020 09:00 AM

Project: Southern Regional HS 9/10

Analytical Results

Client Sample Description SR9-1-RM9-12-CF2
30 **Collected:** 8/14/2020 11:24:00 AM **Lab ID:** 012008720-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.78	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 22:05

Client Sample Description SR9-1-H9-4-WF
31 **Collected:** 8/14/2020 11:28:00 AM **Lab ID:** 012008720-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.10	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 22:07

Client Sample Description SR9-1-RM6-5.1-CF
32 **Collected:** 8/14/2020 11:35:00 AM **Lab ID:** 012008720-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.45	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 22:08

Client Sample Description SR9-1-RM9-10-CF
33 **Collected:** 8/14/2020 11:40:00 AM **Lab ID:** 012008720-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	22.7	1.00 µg/L	8/25/2020 JA	8/26/2020 KB 16:21

Client Sample Description SR9-1-RM9-10-CF2
34 **Collected:** 8/14/2020 11:41:00 AM **Lab ID:** 012008720-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.75	1.00 µg/L	8/25/2020 JA	8/26/2020 KB 16:26

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012008720

CustomerID: PARS51

CustomerPO: 1037-21

ProjectID:

Attn: **Jessica Perrini**
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691

Phone: (609) 890-7277
 Fax: (609) 890-9116
 Received: 8/17/2020 09:00 AM

Project: Southern Regional HS 9/10

Analytical Results

Client Sample Description SR9-1-RM9-9-CF1 **Collected:** 8/14/2020 **Lab ID:** 012008720-0036
 35 11:43:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.96	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 22:12

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Jessica Perrini
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691

8/31/2020

Phone: (609) 890-7277
Fax: (609) 890-9116

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 8/17/2020. The results are tabulated on the attached data pages for the following client designated project:

Southern Regional

The reference number for these samples is EMSL Order #012008715. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012008715

CustomerID: PARS51

CustomerPO: 1037-21

ProjectID:

Attn: **Jessica Perrini**
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691

Phone: (609) 890-7277
 Fax: (609) 890-9116
 Received: 8/17/2020 09:00 AM

Project: Southern Regional

Analytical Results

Client Sample Description SRMS-Field Blank **Collected:** 8/15/2020 7:48:00 AM **Lab ID:** 012008715-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 19:27

Client Sample Description SRMS-1-HGYMA-WF1 **Collected:** 8/15/2020 7:50:00 AM **Lab ID:** 012008715-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.30	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 19:32

Client Sample Description SRMS-1-HGYMA-WF2 **Collected:** 8/15/2020 7:51:00 AM **Lab ID:** 012008715-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.42	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 19:34

Client Sample Description SRMS-1-HGYMA-BF **Collected:** 8/15/2020 7:52:00 AM **Lab ID:** 012008715-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 19:35

Client Sample Description SRMS-1-HD-6-WF1 **Collected:** 8/15/2020 7:59:00 AM **Lab ID:** 012008715-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.02	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 19:39

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012008715
 CustomerID: PARS51
 CustomerPO: 1037-21
 ProjectID:

Attn: **Jessica Perrini**
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691

Phone: (609) 890-7277
 Fax: (609) 890-9116
 Received: 8/17/2020 09:00 AM

Project: **Southern Regional**

Analytical Results

Client Sample Description SRMS-1-HD-6-WF2 **Collected:** 8/15/2020 8:01:00 AM **Lab ID:** 012008715-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.60	1.00 µg/L	8/26/2020 VD	8/26/2020 19:40 KB

Client Sample Description SRMS-1-RMD-6-CF **Collected:** 8/15/2020 8:03:00 AM **Lab ID:** 012008715-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.72	1.00 µg/L	8/26/2020 VD	8/26/2020 19:41 KB

Client Sample Description SRMS-1-RMB-1-CF **Collected:** 8/15/2020 8:04:00 AM **Lab ID:** 012008715-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	8/26/2020 VD	8/26/2020 19:43 KB

Client Sample Description SRMS-1-HGIRLRM-NWING-BF **Collected:** 8/15/2020 8:06:00 AM **Lab ID:** 012008715-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	8/26/2020 VD	8/26/2020 19:44 KB

Client Sample Description SRMS-1-HGIRLRM-NWING-WC **Collected:** 8/15/2020 8:07:00 AM **Lab ID:** 012008715-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.41	1.00 µg/L	8/26/2020 VD	8/26/2020 19:45 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	012008715
CustomerID:	PARS51
CustomerPO:	1037-21
ProjectID:	

Attn: **Jessica Perrini**
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691

Phone: (609) 890-7277
 Fax: (609) 890-9116
 Received: 8/17/2020 09:00 AM

Project: Southern Regional

Analytical Results

Client Sample Description SRMS-1-HN-WING-WF1 **Collected:** 8/15/2020 8:10:00 AM **Lab ID:** 012008715-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.94	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 19:46

Client Sample Description SRMS-1-HN-WING-WF2 **Collected:** 8/15/2020 8:11:00 AM **Lab ID:** 012008715-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.21	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 19:50

Client Sample Description SRMS-1-H-D-3-WF **Collected:** 8/15/2020 8:13:00 AM **Lab ID:** 012008715-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.83	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 19:54

Client Sample Description SRMS-1-RMB-11-TF1 **Collected:** 8/15/2020 8:18:00 AM **Lab ID:** 012008715-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.05	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 19:55

Client Sample Description SRMS-1-RMB-11-TF2 **Collected:** 8/15/2020 8:19:00 AM **Lab ID:** 012008715-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	24.5	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 19:57

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012008715

CustomerID: PARS51

CustomerPO: 1037-21

ProjectID:

Attn: **Jessica Perrini**
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691

Phone: (609) 890-7277
 Fax: (609) 890-9116
 Received: 8/17/2020 09:00 AM

Project: **Southern Regional****Analytical Results**

Client Sample Description SRMS-1-HE-10-WF1 **Collected:** 8/15/2020 8:25:00 AM **Lab ID:** 012008715-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.19	1.00 µg/L	8/26/2020 VD	8/26/2020 19:58 KB

Client Sample Description SRMS-1-HE-10-WF2 **Collected:** 8/15/2020 8:26:00 AM **Lab ID:** 012008715-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.56	1.00 µg/L	8/26/2020 VD	8/26/2020 19:59 KB

Client Sample Description SRMS-1-HE-5-WF1 **Collected:** 8/15/2020 8:27:00 AM **Lab ID:** 012008715-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	30.5	1.00 µg/L	8/26/2020 VD	8/26/2020 20:01 KB

Client Sample Description SRMS-1-HE-5-WF2 **Collected:** 8/15/2020 8:28:00 AM **Lab ID:** 012008715-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.78	1.00 µg/L	8/26/2020 VD	8/26/2020 20:02 KB

Client Sample Description SRMS-1-HE-5-WF3 **Collected:** 8/15/2020 8:29:00 AM **Lab ID:** 012008715-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.83	1.00 µg/L	8/26/2020 VD	8/26/2020 20:03 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012008715

CustomerID: PARS51

CustomerPO: 1037-21

ProjectID:

Attn: **Jessica Perrini**
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691

Phone: (609) 890-7277
 Fax: (609) 890-9116
 Received: 8/17/2020 09:00 AM

Project: Southern Regional

Analytical Results

Client Sample Description SRMS-1-CAFE-WC1 **Collected:** 8/15/2020 8:30:00 AM **Lab ID:** 012008715-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 20:11

Client Sample Description SRMS-1-CAFE-BF **Collected:** 8/15/2020 8:30:00 AM **Lab ID:** 012008715-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 20:15

Client Sample Description SRMS-1-KIT-FP **Collected:** 8/15/2020 8:32:00 AM **Lab ID:** 012008715-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.51	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 20:16

Client Sample Description SRMS-1-KIT-IM **Collected:** 8/15/2020 8:31:00 AM **Lab ID:** 012008715-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	8/25/2020 JA	8/26/2020 KB 16:11

Client Sample Description SRMS-1-HE-E-3-CF1 **Collected:** 8/15/2020 8:39:00 AM **Lab ID:** 012008715-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.95	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 20:17

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	012008715
CustomerID:	PARS51
CustomerPO:	1037-21
ProjectID:	

Attn: **Jessica Perrini**
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691

Phone: (609) 890-7277
 Fax: (609) 890-9116
 Received: 8/17/2020 09:00 AM

Project: **Southern Regional****Analytical Results**

Client Sample Description SRMS-1-HE-E-3-CF2 **Collected:** 8/15/2020 8:40:00 AM **Lab ID:** 012008715-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.60	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 20:18

Client Sample Description SRMS-1-HE-E-3-CF3 **Collected:** 8/15/2020 8:41:00 AM **Lab ID:** 012008715-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.08	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 20:20

Client Sample Description SRMS-1-HE-E-3-CF4 **Collected:** 8/15/2020 8:41:00 AM **Lab ID:** 012008715-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.18	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 20:21

Client Sample Description SRMS-1-HE-E-3-CF5 **Collected:** 8/15/2020 8:43:00 AM **Lab ID:** 012008715-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.28	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 20:25

Client Sample Description SRMS-1-HE-E-3-CF6 **Collected:** 8/15/2020 8:44:00 AM **Lab ID:** 012008715-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.89	1.00 µg/L	8/26/2020 VD	8/26/2020 KB 20:26

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012008715
 CustomerID: PARS51
 CustomerPO: 1037-21
 ProjectID:

Attn: **Jessica Perrini**
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691

Phone: (609) 890-7277
 Fax: (609) 890-9116
 Received: 8/17/2020 09:00 AM

Project: **Southern Regional**

Analytical Results

Client Sample Description SRMS-1-LIBOFFICE-TF **Collected:** 8/15/2020 8:49:00 AM **Lab ID:** 012008715-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.7	1.00 µg/L	8/26/2020 VD	8/26/2020 20:27 KB

Client Sample Description SRMS-1-DWINGTEACHERLOUG-TF **Collected:** 8/15/2020 8:50:00 AM **Lab ID:** 012008715-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.60	1.00 µg/L	8/26/2020 VD	8/26/2020 20:29 KB

Client Sample Description SRMS-1-HA-1-BF **Collected:** 8/15/2020 8:54:00 AM **Lab ID:** 012008715-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	8/26/2020 VD	8/26/2020 20:32 KB

Client Sample Description SRMS-1-NURSEOFFICE-NS **Collected:** 8/15/2020 8:55:00 AM **Lab ID:** 012008715-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	8/26/2020 VD	8/26/2020 20:34 KB

Client Sample Description SRMS-1-MAINFOFFICE-WC **Collected:** 8/15/2020 8:56:00 AM **Lab ID:** 012008715-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	11.6	1.00 µg/L	8/26/2020 VD	8/26/2020 20:35 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order:	012008715
CustomerID:	PARS51
CustomerPO:	1037-21
ProjectID:	

Attn: **Jessica Perrini**
PARS Environmental
500 Horizon Drive
Suite 540
Robbinsville, NJ 08691

Phone: (609) 890-7277
Fax: (609) 890-9116
Received: 8/17/2020 09:00 AM

Project: **Southern Regional****Analytical Results**

Client Sample Description SRMS-1-MAINOFFICE-TF **Collected:** 8/15/2020 8:58:00 AM **Lab ID:** 012008715-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.23	1.00 µg/L	8/26/2020 VD	8/26/2020 20:36 KB

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results

Field ID	Flushed Y/N	Laboratory Sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
SRMS-Field Blank	N	012008715-0001	EMSL	03036	8/15/2020	7:48	200.8	8/26/2020	19:27	<1.00	1.00	1	N	
SRMS-1-HGYMA-WF1	N	012008715-0002	EMSL	03036	8/15/2020	7:50	200.8	8/26/2020	19:32	1.30	1.00	1	N	
SRMS-1-HGYMA-WF2	N	012008715-0003	EMSL	03036	8/15/2020	7:51	200.8	8/26/2020	19:34	1.42	1.00	1	N	
SRMS-1-HGYMA-BF	N	012008715-0004	EMSL	03036	8/15/2020	7:52	200.8	8/26/2020	19:35	<1.00	1.00	1	N	
SRMS-1-HD-6-WF1	N	012008715-0005	EMSL	03036	8/15/2020	7:59	200.8	8/26/2020	19:39	1.02	1.00	1	N	
SRMS-1-HD-6-WF2	N	012008715-0006	EMSL	03036	8/15/2020	8:01	200.8	8/26/2020	19:40	2.60	1.00	1	N	
SRMS-1-RMD-6-CF	N	012008715-0007	EMSL	03036	8/15/2020	8:03	200.8	8/26/2020	19:41	2.72	1.00	1	N	
SRMS-1-RMB-1-CF	N	012008715-0008	EMSL	03036	8/15/2020	8:04	200.8	8/26/2020	19:43	<1.00	1.00	1	N	
SRMS-1-HGIRLRM-NWING-BF	N	012008715-0009	EMSL	03036	8/15/2020	8:06	200.8	8/26/2020	19:44	<1.00	1.00	1	N	
SRMS-1-HGIRLRM-NWING-WC	N	012008715-0010	EMSL	03036	8/15/2020	8:07	200.8	8/26/2020	19:45	2.41	1.00	1	N	
SRMS-1-HN-WING-WF1	N	012008715-0011	EMSL	03036	8/15/2020	8:10	200.8	8/26/2020	19:46	7.94	1.00	1	N	
SRMS-1-HN-WING-WF2	N	012008715-0012	EMSL	03036	8/15/2020	8:11	200.8	8/26/2020	19:50	7.21	1.00	1	N	
SRMS-1-H-D-3-WF	N	012008715-0013	EMSL	03036	8/15/2020	8:13	200.8	8/26/2020	19:54	1.83	1.00	1	N	
SRMS-1-RMB-11-TF1	N	012008715-0014	EMSL	03036	8/15/2020	8:18	200.8	8/26/2020	19:55	8.05	1.00	1	N	
SRMS-1-RMB-11-TF2	N	012008715-0015	EMSL	03036	8/15/2020	8:19	200.8	8/26/2020	19:57	24.5	1.00	1	N	
SRMS-1-HE-10-WF1	N	012008715-0016	EMSL	03036	8/15/2020	8:25	200.8	8/26/2020	19:58	6.19	1.00	1	N	
SRMS-1-HE-10-WF2	N	012008715-0017	EMSL	03036	8/15/2020	8:26	200.8	8/26/2020	19:59	2.56	1.00	1	N	
SRMS-1-HE-5-WF1	N	012008715-0018	EMSL	03036	8/15/2020	8:27	200.8	8/26/2020	20:01	30.5	1.00	1	N	
SRMS-1-HE-5-WF2	N	012008715-0019	EMSL	03036	8/15/2020	8:28	200.8	8/26/2020	20:02	2.78	1.00	1	N	
SRMS-1-HE-5-WF3	N	012008715-0020	EMSL	03036	8/15/2020	8:29	200.8	8/26/2020	20:03	1.83	1.00	1	N	
SRMS-1-CAFE-WC1	N	012008715-0021	EMSL	03036	8/15/2020	8:30	200.8	8/26/2020	20:11	<1.00	1.00	1	N	
SRMS-1-CAFE-BF	N	012008715-0022	EMSL	03036	8/15/2020	8:30	200.8	8/26/2020	20:15	<1.00	1.00	1	N	
SRMS-1-KIT-FP	N	012008715-0023	EMSL	03036	8/15/2020	8:32	200.8	8/26/2020	20:16	1.51	1.00	1	N	
SRMS-1-KIT-IM	N	012008715-0024	EMSL	03036	8/15/2020	8:31	200.8	8/26/2020	16:11	<1.00	1.00	1	N	
SRMS-1-HE-E-3-CF1	N	012008715-0025	EMSL	03036	8/15/2020	8:39	200.8	8/26/2020	20:17	3.95	1.00	1	N	
SRMS-1-HE-E-3-CF2	N	012008715-0026	EMSL	03036	8/15/2020	8:40	200.8	8/26/2020	20:18	2.60	1.00	1	N	
SRMS-1-HE-E-3-CF3	N	012008715-0027	EMSL	03036	8/15/2020	8:41	200.8	8/26/2020	20:20	1.08	1.00	1	N	
SRMS-1-HE-E-3-CF4	N	012008715-0028	EMSL	03036	8/15/2020	8:41	200.8	8/26/2020	20:21	2.18	1.00	1	N	
SRMS-1-HE-E-3-CF5	N	012008715-0029	EMSL	03036	8/15/2020	8:43	200.8	8/26/2020	20:25	4.28	1.00	1	N	
SRMS-1-HE-E-3-CF6	N	012008715-0030	EMSL	03036	8/15/2020	8:44	200.8	8/26/2020	20:26	1.89	1.00	1	N	
SRMS-1-LIBOFFICE-TF	N	012008715-0031	EMSL	03036	8/15/2020	8:49	200.8	8/26/2020	20:27	12.7	1.00	1	N	
SRMS-1-DWINGTEACHERLOUG-TF	N	012008715-0032	EMSL	03036	8/15/2020	8:50	200.8	8/26/2020	20:29	1.60	1.00	1	N	
SRMS-1-HA-1-BF	N	012008715-0033	EMSL	03036	8/15/2020	8:54	200.8	8/26/2020	20:32	<1.00	1.00	1	N	
SRMS-1-NURSEOFFICE-NS	N	012008715-0034	EMSL	03036	8/15/2020	8:55	200.8	8/26/2020	20:34	<1.00	1.00	1	N	
SRMS-1-MAINFOFFICE-WC	N	012008715-0035	EMSL	03036	8/15/2020	8:56	200.8	8/26/2020	20:35	11.6	1.00	1	N	
SRMS-1-MAINFOFFICE-TF	N	012008715-0036	EMSL	03036	8/15/2020	8:58	200.8	8/26/2020	20:36	1.23	1.00	1	N	

Exceeds EPA Action Limit (> 15.5ppb)

Bldg ID - Room / Location ID / Floor - Outlet Type / Number in Sequence - (P)rimary / (F)lush

OUTLET TYPE

- BF = Bottle Faucet
- CF = Classroom Faucet
- WF = Drinking Water Fountain
- FP = Food Prep
- HS = Hand Sink
- IM = Ice Machine
- KC = Kitchen Outlet, Cold
- KT= Kettle
- SB = Sink Bubbler Combination
- SS = Slop Sink
- TF = Teachers Faucet
- WC = Water Cooler
- KF=Kitchen Faucet

Field ID	Flushed Y/N	Laboratory Sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
FB- Field Blank	N	012008726-0001	EMSL	03036	8/14/2020	7:20	200.8	8/26/2020	22:17	<1.00	1.00	1	N	
SR11-1-H108-WC1	N	012008726-0002	EMSL	03036	8/14/2020	7:26	200.8	8/26/2020	22:21	3.09	1.00	1	N	
SR11-1-H108-WC2	N	012008726-0003	EMSL	03036	8/14/2020	7:27	200.8	8/26/2020	22:22	13.1	1.00	1	N	
SR11-1-H108-WC3	N	012008726-0004	EMSL	03036	8/14/2020	7:29	200.8	8/26/2020	22:23	<1.00	1.00	1	N	
SR11-1-H108-WC4	N	012008726-0005	EMSL	03036	8/14/2020	7:31	200.8	8/26/2020	22:30	1.48	1.00	1	N	
SR11-1-NSOFFICEEX1-NS1	N	012008726-0006	EMSL	03036	8/14/2020	7:39	200.8	8/26/2020	22:31	1.12	1.00	1	N	
SR11-1-NSOFFICEEX1-NS2	N	012008726-0007	EMSL	03036	8/14/2020	7:40	200.8	8/26/2020	22:32	2.67	1.00	1	N	
SR11-1-NSOFFICEEX1-NS3	N	012008726-0008	EMSL	03036	8/14/2020	7:41	200.8	8/26/2020	22:34	2.85	1.00	1	N	
SR11-1-NSOFFICE-BF2	N	012008726-0009	EMSL	03036	8/14/2020	7:43	200.8	8/26/2020	22:35	2.77	1.00	1	N	
SR11-1-NSOFFICE-BF1	N	012008726-0010	EMSL	03036	8/14/2020	7:45	200.8	8/26/2020	22:36	2.84	1.00	1	N	
SR11-1-HNURSEOFFICE-WC1	N	012008726-0011	EMSL	03036	8/14/2020	7:50	200.8	8/26/2020	22:37	<1.00	1.00	1	N	
SR11-1-HNURSEOFFICE-WC2	N	012008726-0012	EMSL	03036	8/14/2020	7:51	200.8	8/26/2020	22:44	<1.00	1.00	1	N	
SR11-1-WEIGHTRM-WC1	N	012008726-0013	EMSL	03036	8/14/2020	7:53	200.8	8/26/2020	16:06	6.99	1.00	1	N	
SR11-1-WEIGHTRM-WC2	N	012008726-0014	EMSL	03036	8/14/2020	7:54	200.8	8/26/2020	22:45	<1.00	1.00	1	N	
SR11-1-HWEIGHT-BF	N	012008726-0015	EMSL	03036	8/14/2020	7:55	200.8	8/26/2020	22:46	<1.00	1.00	1	N	
SR11-1-GLOCKERRM-WC1	N	012008726-0016	EMSL	03036	8/14/2020	7:56	200.8	8/26/2020	22:48	<1.00	1.00	1	N	
SR11-1-GLOCKERRM-WC2	N	012008726-0017	EMSL	03036	8/14/2020	8:08	200.8	8/26/2020	22:49	1.36	1.00	1	N	
SR11-1-GTEAMRM-WC1	N	012008726-0018	EMSL	03036	8/14/2020	8:09	200.8	8/26/2020	22:50	1.45	1.00	1	N	
SR11-1-GTEAMRM-WC2	N	012008726-0019	EMSL	03036	8/14/2020	8:12	200.8	8/26/2020	22:51	4.61	1.00	1	N	
SR11-1-BTEAMRM-WC1	N	012008726-0020	EMSL	03036	8/14/2020	8:15	200.8	8/26/2020	22:53	<1.00	1.00	1	N	
SR11-1-BTEAMRM-WC2	N	012008726-0021	EMSL	03036	8/14/2020	8:20	200.8	8/26/2020	22:54	6.33	1.00	1	N	
SR11-1-BLOCKERRM-WC1	N	012008726-0022	EMSL	03036	8/14/2020	8:21	200.8	8/26/2020	23:02	13.9	1.00	1	N	
SR11-1-BLOCKERRM-WC2	N	012008726-0023	EMSL	03036	8/14/2020	8:22	200.8	8/27/2020	14:22	<1.00	1.00	1	N	
SR11-1-HWRESTLING-BF	N	012008726-0024	EMSL	03036	8/14/2020	8:30	200.8	8/26/2020	23:05	<1.00	1.00	1	N	
SR11-1-HWRESTLING-WC	N	012008726-0025	EMSL	03036	8/14/2020	8:31	200.8	8/26/2020	23:07	<1.00	1.00	1	N	
SR11-1-WRESTLINGGYM-WC	N	012008726-0026	EMSL	03036	8/14/2020	8:35	200.8	8/26/2020	23:08	<1.00	1.00	1	N	
SR11-1-WRESTLINGGYM-WC1	N	012008726-0027	EMSL	03036	8/14/2020	8:36	200.8	8/26/2020	23:09	<1.00	1.00	1	N	
SR11-1-WRESTLINGGYM-WC2	N	012008726-0028	EMSL	03036	8/14/2020	8:37	200.8	8/26/2020	23:13	1.91	1.00	1	N	
SR11-1-HASOUTH-BF	N	012008726-0029	EMSL	03036	8/14/2020	8:40	200.8	8/26/2020	23:14	<1.00	1.00	1	N	
SR11-1-CHILDS.T.-TF	N	012008726-0030	EMSL	03036	8/14/2020	8:43	200.8	8/26/2020	23:16	<1.00	1.00	1	N	
SR11-1-LIB-WC1	N	012008726-0031	EMSL	03036	8/14/2020	8:50	200.8	8/26/2020	23:17	<1.00	1.00	1	N	
SR11-1-LIB-WC2	N	012008726-0032	EMSL	03036	8/14/2020	8:52	200.8	8/26/2020	23:18	<1.00	1.00	1	N	
SR11-1-LIBOFFICE-TF	N	012008726-0033	EMSL	03036	8/14/2020	8:54	200.8	8/26/2020	23:19	<1.00	1.00	1	N	
SR11-1-HOMEECO-KF-1	N	012008726-0034	EMSL	03036	8/14/2020	8:55	200.8	8/26/2020	23:23	<1.00	1.00	1	N	
SR11-1-HOMEECO-KF-2	N	012008726-0035	EMSL	03036	8/14/2020	9:00	200.8	8/26/2020	23:24	<1.00	1.00	1	N	
SR11-1-HOMEECO-KF-3	N	012008726-0036	EMSL	03036	8/14/2020	9:01	200.8	8/26/2020	23:28	<1.00	1.00	1	N	
SR11-1-HOMEECO-KF-4	N	012008726-0037	EMSL	03036	8/14/2020	9:02	200.8	8/26/2020	23:30	<1.00	1.00	1	N	
SR11-1-HOMEECO-KF-5	N	012008726-0038	EMSL	03036	8/14/2020	9:02	200.8	8/26/2020	23:31	<1.00	1.00	1	N	
SR11-1-HOMEECO-KF-6	N	012008726-0039	EMSL	03036	8/14/2020	9:03	200.8	8/26/2020	23:32	<1.00	1.00	1	N	
SR11-1-MCAFE-WC1	N	012008726-0040	EMSL	03036	8/14/2020	9:05	200.8	8/26/2020	23:33	<1.00	1.00	1	N	
SR11-1-MCAFE-BF	N	012008726-0041	EMSL	03036	8/14/2020	9:06	200.8	8/26/2020	23:35	<1.00	1.00	1	N	
SR11-RM101-BF	N	012008726-0042	EMSL	03036	8/14/2020	9:10	200.8	8/26/2020	23:36	5.79	1.00	1	N	
SR11-RM101-CF1	N	012008726-0043	EMSL	03036	8/14/2020	9:12	200.8	8/26/2020	23:44	1.96	1.00	1	N	
SR11-RM101-CF2	N	012008726-0044	EMSL	03036	8/14/2020	9:13	200.8	8/26/2020	23:47	4.87	1.00	1	N	
SR11-1-CAFE-WC	N	012008726-0045	EMSL	03036	8/14/2020	9:14	200.8	8/26/2020	23:49	1.85	1.00	1	N	
SR11-1-CAFETEACHER-TF	N	012008726-0046	EMSL	03036	8/14/2020	9:15	200.8	8/26/2020	23:50	8.48	1.00	1	N	
SR11-1-CAFE-WC2	N	012008726-0047	EMSL	03036	8/14/2020	9:18	200.8	8/26/2020	23:51	<1.00	1.00	1	N	
SR11-1-KIT-KF	N	012008726-0048	EMSL	03036	8/14/2020	9:19	200.8	8/26/2020	23:52	3.85	1.00	1	N	
SR11-2-H208-BF	N	012008726-0049	EMSL	03036	8/14/2020	9:25	200.8	8/26/2020	23:54	<1.00	1.00	1	N	
SR11-2-H208-WC1	N	012008726-0050	EMSL	03036	8/14/2020	9:26	200.8	8/26/2020	23:55	3.11	1.00	1	N	
SR11-2-H208-WC2	N	012008726-0051	EMSL	03036	8/14/2020	9:27	200.8	8/27/2020	0:01	<1.00	1.00	1	N	
SR11-2-H208-WC3	N	012008726-0052	EMSL	03036	8/14/2020	9:28	200.8	8/27/2020	0:03	3.44	1.00	1	N	
SR11-2-H224-WC	N	012008726-0053	EMSL	03036	8/14/2020	9:29	200.8	8/27/2020	0:04	<1.00	1.00	1	N	
SR11-2-H227-WC	N	012008726-0054	EMSL	03036	8/14/2020	9:32	200.8	8/27/2020	0:08	1.16	1.00	1	N	

SR11-2-TEACHERLOUG-TF	N	012008726-0055	EMSL	03036	8/14/2020	9:33	200.8	8/27/2020	0:09	<1.00	1.00	1	N	
-----------------------	---	----------------	------	-------	-----------	------	-------	-----------	------	-------	------	---	---	--

Exceeds EPA Action Limit (> 15.5ppb)

Bldg ID - Room / Location ID / Floor - Outlet Type / Number in Sequence - (P)rimary / (F)lush

OUTLET TYPE

BF = Bottle Faucet

CF = Classroom Faucet

WF = Drinking Water Fountain

FP = Food Prep

HS = Hand Sink

IM = Ice Machine

KC = Kitchen Outlet, Cold

KT= Kettle

SB = Sink Bubbler Combination

SS = Slop Sink

TF = Teachers Faucet

WC = Water Cooler

KF=Kitchen Faucet

Field ID	Flushed Y/N	Laboratory Sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
SR-11-Field Blank	N	012008725-0001	EMSL	03036	8/15/2020	7:01	200.8	8/25/2020	15:03	<1.00	1.00	1	N	
SR11-1.H.A.SOUTH-WC	N	012008725-0002	EMSL	03036	8/15/2020	7:05	200.8	8/25/2020	15:05	5.00	1.00	1	N	
SR11-1-KIT-KT	N	012008725-0003	EMSL	03036	8/15/2020	7:09	200.8	8/25/2020	15:06	1.47	1.00	1	N	

Exceeds EPA Action Limit (> 15.5ppb)

Bldg ID - Room / Location ID / Floor - Outlet Type / Number in Sequence - (P)rimary / (F)lush

OUTLET TYPE

- BF = Bottle Faucet
- CF = Classroom Faucet
- WF = Drinking Water Fountain
- FP = Food Prep
- HS = Hand Sink
- IM = Ice Machine
- KC = Kitchen Outlet, Cold
- KT= Kettle
- SB = Sink Bubbler Combination
- SS = Slop Sink
- TF = Teachers Faucet
- WC = Water Cooler
- KF=Kitchen Faucet